



1099 Wall Street West, Suite 275
Lyndhurst, NJ 07071
Tel: (201) 222-5322
Fax: (201) 222-2442
www.tadcosolutions.com

October 1st 2024

Mr. Kevin Brown
796 East Hazelwood Avenue
Rahway, NJ 07065

kbrown@rahwaycao.org

**Reference: Limited Lead/Copper in Drinking Water Sampling Results
796 East Hazelwood Avenue
Rahway, NJ 07065
TADCO ID: J-021524**

Dear Mr. Brown:

At your request TADCO conducted limited screening of drinking water at above referenced property. The purpose of the screening is to assess drinking water used at the subject property for Lead and Copper as per the licensing and renewal requirements set forth by the New Jersey Department of Child and Families (DCF).

Below is a summary table highlighting all Lead and Copper results pertaining to all collected and analyzed samples as well as their locations. A copy of these results has been attached as well for your convenience.

| <u>Sample ID</u> | <u>Sample Location</u> | <u>Copper Result (ug/L)</u> | <u>Lead Result (ug/L)</u> |
|------------------|---------------------------------|-----------------------------|---------------------------|
| 24I0998-01 | Preschool Room 1 | 58.8 | <1.0 |
| 24I0998-02 | Toddler Room 1 | 47.8 | <1.0 |
| 24I0998-03 | Kitchen | 58.5 | <1.0 |
| 24I0998-04 | 1 st Floor Rest Room | 38.5 | <1.0 |
| 24I0998-05 | 2 nd Floor Rest Room | 115 | <1.0 |
| 24I0998-06 | Preschool Room 4 | 31.3 | <1.0 |

In accordance with N.J.A.C. 3A:52-5.3(i)(5)(i), these results should be submitted to your DFC Inspector, DCF Office of Licensing or whomever is currently handling your renewal application.

We trust that you will find this information helpful. If we can be of further assistance, please do not hesitate to contact us.

With regards,



Safwat Tadrous, P.E., Managing Member
NJ PE 24GE03716800